

Number	18-003201-PR01 (NW Z04-A01-04-en-01)
Owner	Europa Profil Aluminium S.A. 56th Klm National Highway Athens - Lamia 32011 Innofita Viotas Greece
Product	Single-leaf tilt-and turn single window
Designation	Shipping name: Europa 5500
Details	Manufacturer Europa Profil Aluminium S.A., - Athens - Lamia; Type of opening Tilt and turn; Overall dimensions (W x H) 1230 mm x 1480 mm; Rebate seal levels 3; Mass, area-related 52.4 kg/m ² ; Number of casements 1; IGU: Glass configuration LSG acoustic (64.2) 10 / Air 20 / LSG acoustic (46.2) 10; Frame member: Designation TH5594; Material Aluminium with thermal break; Projected width 50 mm; Structural depth 70.5 mm; Casement member: Designation TH5711; Material Aluminium with thermal break; Projected width 76.2 mm; Structural depth 80.9 mm

Special features

Result

Weighted Sound Reduction Index R_w and Spectrum-Adaptation Terms C and C_{tr} according to EN ISO 10140-2:2010-09, EN ISO 717-1:2013-03




$$R_w (C; C_{tr}) = 45 (-1; -4) \text{ dB}$$

Basis *)

EN ISO 10140-2:2010-09
EN ISO 717-1:2013-03
EN ISO 10140-1:2016-08
*) and corresponding national versions (e.g. DIN EN)
Test report: 18-003201-PR01 PB Z04-A01-04-en-01

Representation



Instructions for use

The results obtained can be used as evidence in accordance with the above basis.

Validity

There is no time limit.
When using this document the up-to-dateness of above basis and the conformity of the product have to be observed.

Notes on publication

The ift-Guidance Sheet "Conditions and Guidance for the Use of ift Test Documents" applies.

ift Rosenheim
16.04.2019

Bernd Saß

Bernd Saß, Dipl.-Ing. (FH)
Deputy Head of Testing Department
Building Acoustics

F. Brechleier

Florian Brechleier, MSc, Dipl.-Ing. (FH)
Operating Testing Officer
Building Acoustics

Identity-Check



www.ift-rosenheim.de/ift-geprueft
ID: 26C-96AE8