

Number	18-003201-PR02 (NW Z05-A01-04-en-01)
Owner	Europa Profil Aluminio S.A. 56th Klm National Highway Athens - Lamia 32011 Innofita Viotas Greece
Product	Lifting sliding door (Type A)
Designation	Shipping name: Europa A40 SL Sliding with fixed light
Details	Manufacturer Europa Profil Aluminium S.A., - Athens - Lamia; Material Aluminium system with thermal break; Type of opening Lifting sliding; Overall dimensions (W x H) 2660 mm x 2500 mm; Rebate seal levels sealing levels: Top & bottom: 4; middle section: 6, lock side: 5; Mass, area-related 53.7 kg/m ² ; Number of sashes 1; IGU: Glass configuration LSG (64.2) 10 / Air 14 / LSG (46.2) 10; Thickness 34 mm; Frame: Designation TH11101; Projected width 42 mm; Structural depth 149 mm; Sash: Designation TH11201; Projected width 84 mm; Structural depth 50 mm

Special features

Result

Weighted Sound Reduction Index R_w and Spectrum-Adaptation Terms C and C_{tr} according to EN ISO 10140-2:2010-09, EN ISO 717-1:2013-03




$$R_w (C; C_{tr}) = 43 (-1; -5) \text{ dB}$$

Basis *)

EN ISO 10140-2:2010-09
EN ISO 717-1:2013-03
EN ISO 10140-1:2016-08
*) and corresponding national versions (e.g. DIN EN)

Test report: 18-003201-PR02 PB Z05-A01-04-en-01

Representation



Instructions for use

The results obtained can be used as evidence in accordance with the above basis.

Validity

There is no time limit. When using this document the up-to-dateness of above basis and the conformity of the product have to be observed.

Notes on publication

The ift-Guidance Sheet "Conditions and Guidance for the Use of ift Test Documents" applies.

ift Rosenheim
24.04.2019

Bernd Saß

Bernd Saß, Dipl.-Ing. (FH)
Deputy Head of Testing Department
Building Acoustics

F. Brechleier

Florian Brechleier, MSc, Dipl.-Ing. (FH)
Operating Testing Officer
Building Acoustics

Identity-Check



www.ift-rosenheim.de/ift-geprueft
ID: 67D-A7CF9